



State of Vermont

Department of Fish and Wildlife
Department of Forests, Parks and Recreation
Department of Environmental Conservation
State Geologist
Natural Resources Conservation Council
RELAY SERVICE FOR THE HEARING IMPAIRED
1-800-253-0191 TDD>Voice
1-800-253-0195 Voice>TDD

AGENCY OF NATURAL RESOURCES
Department of Environmental Conservation
Hazardous Materials Management Division
103 South Main Street / West Building
Waterbury, Vermont 05671-0404
802-241-3888
FAX 802-241-3296

May 2, 1995

Donald Hart
Selectman
Town of Weston
P.O. Box 98
Weston, VT 05161

RE: Sites Management Activity Complete at Weston Town Garage
(Site #94-1622)

Dear Mr. Hart:

The Sites Management Section (SMS) has received and reviewed the April 19, 1995 summary report that Bruce Cox of Dufresne-Henry, Inc. has developed for the above referenced site. Groundwater samples collected from the four onsite monitoring wells (MWs) in March, 1995 were all non-detectable for BTEX and MTBE compounds. With the results of this recent groundwater analysis, the SMS can now conclude the following at this site:

- * Two underground storage tanks (USTs) owned by the Town of Weston were removed on May 25, 1994. During the tank pull, soils screened near the diesel pump dispenser had peak concentrations of 55 ppm as measured by a photoionization detector. A total of twelve cubic yards of petroleum contaminated soils were removed from this area and polyencapsulated onsite. Background concentrations of volatile organic compounds were detected in the tank basins of the two tanks. No sheens were observed on the water table encountered at a depth of approximately five feet below ground surface.
- * The twelve cubic yards of petroleum contaminated soils were transported offsite for asphalt batching.
- * As stated above, the latest groundwater results are all non-detectable for BTEX and MTBE compounds.
- * There have been no receptors identified which are at risk from the contamination observed onsite.

Based on the above, the SMS is designating this site as Sites Management Activity Complete (SMAC). A SMAC designation does not relieve the Town of Weston of the liability associated with

any past or present contamination onsite. It does, however, mean that the SMS is not requesting any additional work in response to the May 25, 1994, UST removal, at this time. The SMS appreciates your cooperation in conducting the necessary investigation at this site. Please feel free to call with any questions or concerns.

Sincerely,

A handwritten signature in dark ink, appearing to read "Chuck Schwer", with a stylized flourish at the end.

Chuck Schwer, Acting Chief
Sites Management Section

CC: Bruce Cox, Dufresne-Henry, Inc.
DEC Regional Office

JP/ua/941622SMAC